

Page 1 of 3

EXECUTIVE SUMMARY - ENFORCEMENT MATTER
DOCKET NO.: 2007-1261-PST-E TCEQ ID: RN102455748 CASE NO.: 34400
RESPONDENT NAME: A R H Enterprises, Inc. dba R H Food Mart

ORDER TYPE:		
<input checked="" type="checkbox"/> 1660 AGREED ORDER	<input type="checkbox"/> FINDINGS AGREED ORDER	<input type="checkbox"/> FINDINGS ORDER FOLLOWING SOAH HEARING
<input type="checkbox"/> FINDINGS DEFAULT ORDER	<input type="checkbox"/> SHUTDOWN ORDER	<input type="checkbox"/> IMMINENT AND SUBSTANTIAL ENDANGERMENT ORDER
<input type="checkbox"/> AMENDED ORDER	<input type="checkbox"/> EMERGENCY ORDER	
CASE TYPE:		
<input type="checkbox"/> AIR	<input type="checkbox"/> MULTI-MEDIA (check all that apply)	<input type="checkbox"/> INDUSTRIAL AND HAZARDOUS WASTE
<input type="checkbox"/> PUBLIC WATER SUPPLY	<input checked="" type="checkbox"/> PETROLEUM STORAGE TANKS	<input type="checkbox"/> OCCUPATIONAL CERTIFICATION
<input type="checkbox"/> WATER QUALITY	<input type="checkbox"/> SEWAGE SLUDGE	<input type="checkbox"/> UNDERGROUND INJECTION CONTROL
<input type="checkbox"/> MUNICIPAL SOLID WASTE	<input type="checkbox"/> RADIOACTIVE WASTE	<input type="checkbox"/> DRY CLEANER REGISTRATION
<p>SITE WHERE VIOLATION(S) OCCURRED: R H Food Mart, 3701 Esters Road, Irving, Dallas County</p> <p>TYPE OF OPERATION: Convenience store with retail sales of gasoline</p> <p>SMALL BUSINESS: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>OTHER SIGNIFICANT MATTERS: There are no complaints. There is no record of additional pending enforcement actions regarding this facility location.</p> <p>INTERESTED PARTIES: No one other than the ED and the Respondent has expressed an interest in this matter.</p> <p>COMMENTS RECEIVED: The <i>Texas Register</i> comment period expired on January 22, 2007. No comments were received.</p> <p>CONTACTS AND MAILING LIST:</p> <p style="margin-left: 20px;">TCEQ Attorney/SEP Coordinator: None</p> <p style="margin-left: 20px;">TCEQ Enforcement Coordinator: Ms. Judy Kluge, Enforcement Division, Enforcement Team 6, MC R-04, (817) 588-5825; Mr. Bryan Sinclair, Enforcement Division, MC 219, (512) 239-2171</p> <p style="margin-left: 20px;">Respondent: Mr. Abdul Hameed, President, A R H Enterprises, Inc. dba R H Food Mart, 6529 Timberwolf Trail, Plano, Texas 75093</p> <p style="margin-left: 20px;">Respondent's Attorney: Not represented by counsel on this enforcement matter</p>		

VIOLATION SUMMARY CHART:

VIOLATION INFORMATION	PENALTY CONSIDERATIONS	CORRECTIVE ACTIONS TAKEN/REQUIRED
<p>Type of Investigation: <input type="checkbox"/> Complaint <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Enforcement Follow-up <input type="checkbox"/> Records Review</p> <p>Date(s) of Complaints Relating to this Case: None</p> <p>Date of Investigation Relating to this Case: July 6, 2007</p> <p>Date of NOV/NOE Relating to this Case: August 3, 2007 (NOE)</p> <p>Background Facts: This was a routine investigation. Eight violations were documented.</p> <p>WASTE</p> <p>1) Failure to provide a method of release detection capable of detecting a release from any portion of the underground storage tank ("UST") system which contained regulated substances. Specifically, monthly inventory control was not being conducted and the automatic tank gauge did not have probes installed [30 TEX. ADMIN. CODE § 334.50(a)(1)(A) and TEX. WATER CODE § 26.3475(c)(1)].</p> <p>2) Failure to conduct proper release detection for the product piping associated with the UST system. Specifically, the annual piping tightness tests had not been conducted [30 TEX. ADMIN. CODE § 334.50(b)(2) and TEX. WATER CODE § 26.3475(a)].</p> <p>3) Failure to test the line leak detectors at least once per year for performance and operational reliability. Specifically, the line leak detectors had not been performance tested annually [30 TEX. ADMIN. CODE § 334.50(b)(2)(A)(i)(III) and TEX. WATER CODE § 26.3475(a)].</p> <p>4) Failure to ensure that at least one Station representative received training in the operation and maintenance of the Stage II vapor recovery system, and each current employee receives in-house Stage II vapor recovery training regarding the purpose</p>	<p>Total Assessed: \$8,300</p> <p>Total Deferred: \$1,660 <input checked="" type="checkbox"/> Expedited Settlement <input type="checkbox"/> Financial Inability to Pay</p> <p>SEP Conditional Offset: \$0</p> <p>Total Paid to General Revenue: \$200 (remaining \$6,440 due in 35 monthly payments of \$184 each)</p> <p>Site Compliance History Classification <input checked="" type="checkbox"/> High <input type="checkbox"/> Average <input type="checkbox"/> Poor</p> <p>Person Compliance History Classification <input checked="" type="checkbox"/> High <input type="checkbox"/> Average <input type="checkbox"/> Poor</p> <p>Major Source: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Applicable Penalty Policy: September 2002</p>	<p>Corrective Actions Taken:</p> <p>The Executive Director recognizes that the Respondent has implemented the following corrective measures at the Station:</p> <p>a) The TCEQ DFW Regional Office received documentation verifying that as of July 11, 2007, the Station successfully conducted the required piping tightness and line leak detector tests;</p> <p>b) The TCEQ DFW Regional Office received documentation verifying that Station representative training has been completed and all current employees have received in-house Stage II vapor recovery training as of July 18, 2007;</p> <p>c) As of November 20, 2007, the TCEQ DFW Regional Office received verification that the Respondent installed an approved ORVR compatible Stage II vapor recovery system, replaced the defective nozzles, and posted the Stage II operating instructions on the dispensers; and</p> <p>d) As of November 20, 2007, the TCEQ DFW Regional Office received verification that the Respondent successfully conducted the required annual testing of the Stage II equipment.</p> <p>Ordering Provisions:</p> <p>It is further ordered that the Respondent shall undertake the following technical requirements:</p> <p>a) Within 30 days after the effective date of this Agreed Order, install and implement a release detection method for the UST system, in accordance with 30 TEX. ADMIN. CODE § 334.50; and</p> <p>b) Within 45 days after the effective date of this Agreed Order, submit written certification and include detailed supporting documentation including photographs, receipts, and/or other records to demonstrate compliance with Ordering Provision a.</p>

<p>and operation of the vapor recovery system. Specifically, Stage II training for the Station representative and the employees had not been completed [30 TEX. ADMIN. CODE § 115.248(1) and TEX. HEALTH & SAFETY CODE § 382.085(b)].</p> <p>5) Failure to upgrade the Stage II equipment to onboard refueling vapor recovery ("ORVR") compatible systems [30 TEX. ADMIN. CODE § 115.242(1)(C) and TEX. HEALTH & SAFETY CODE § 382.085(b)].</p> <p>6) Failure to maintain the Stage II Vapor Recovery System in proper operating condition, as specified by the manufacturer and/or any applicable California Air Resource Board Executive Order(s), and free of defects that would impair the effectiveness of the system including, but not limited to absence or disconnection of any component that is a part of the approved system. Specifically, the Stage II air to liquid test indicated that the nozzles were defective and not functioning properly [30 TEX. ADMIN. CODE § 115.242(3) and TEX. HEALTH & SAFETY CODE § 382.085(b)].</p> <p>7) Failure to post operating instructions conspicuously on the front of each gasoline dispensing pump [30 TEX. ADMIN. CODE § 115.242(9) and TEX. HEALTH & SAFETY CODE § 382.085(b)].</p> <p>8) Failure to verify proper operation of the Stage II equipment at least once every 12 months. Specifically, the Stage II annual system compliance testing had not been conducted [30 TEX. ADMIN. CODE § 115.245(2) and TEX. HEALTH & SAFETY CODE § 382.085(b)].</p>		
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	--

Additional ID No(s): PST 66942



Penalty Calculation Worksheet (PCW)

Policy Revision 2 (September 2002)

PCW Revision June 26, 2007

TCEQ

DATES	Assigned	6-Aug-2007	Screening	6-Aug-2007	EPA Due	
	PCW	9-Aug-2007				

RESPONDENT/FACILITY INFORMATION

Respondent	A R H Enterprises, Inc. dba R H Food Mart		
Reg. Ent. Ref. No.	RN102455748		
Facility/Site Region	4 - Dallas/Fort Worth	Major/Minor Source	Minor

CASE INFORMATION

Enf./Case ID No.	34400	No. of Violations	4
Docket No.	2007-1261-PST-E	Order Type	1660
Media Program(s)	Petroleum Storage Tank	Enf. Coordinator	Judy Kluge
Multi-Media		EC's Team	Enforcement Team 6
Admin. Penalty \$ Limit Minimum	\$0	Maximum	\$10,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties)

Subtotal 1 \$7,000

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History -10% Enhancement Subtotals 2, 3, & 7 -\$700Notes Adjustment due to High Performer classification.Culpability No 0% EnhancementSubtotal 4 \$0Notes The Respondent does not meet the culpability criteria.Good Faith Effort to Comply 0% ReductionSubtotal 5 \$0

	Before NOV	NOV to EDPRP/Settlement Offer
Extraordinary	<input type="text"/>	<input type="text"/>
Ordinary	<input type="text"/>	<input type="text"/>
N/A	X	(mark with x)

Notes The Respondent does not meet the good faith criteria.

Total EB Amounts	\$2,334	0% Enhancement* *Capped at the Total EB \$ Amount
Approx. Cost of Compliance	\$6,500	

Subtotal 6 \$0

SUM OF SUBTOTALS 1-7

Final Subtotal \$6,300

OTHER FACTORS AS JUSTICE MAY REQUIRE

 32%Adjustment \$2,000

Reduces or enhances the Final Subtotal by the indicated percentage. (Enter number only; e.g. -30 for -30%.)

Notes Recommended enhancement to capture the avoided cost associated with the violations.Final Penalty Amount \$8,300

STATUTORY LIMIT ADJUSTMENT

Final Assessed Penalty \$8,300

DEFERRAL

 20%Reduction Adjustment -\$1,660

Reduces the Final Assessed Penalty by the indicated percentage. (Enter number only; e.g. 20 for 20% reduction.)

Notes Deferral offered for expedited settlement.

PAYABLE PENALTY

 \$6,640

Screening Date 6-Aug-2007

Docket No. 2007-1261-PST-E

PCW

Respondent A R H Enterprises, Inc. dba R H Food Mart

Policy Revision 2 (September 2002)

Case ID No. 34400

PCW Revision June 26, 2007

Reg. Ent. Reference No. RN102455748

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Judy Kluge

Compliance History Worksheet

>> Compliance History Site Enhancement (Subtotal 2)

Component	Number of...	Enter Number Here	Adjust.
NOVs	Written NOVs with same or similar violations as those in the current enforcement action (number of NOVs meeting criteria)	0	0%
	Other written NOVs	0	0%
Orders	Any agreed final enforcement orders containing a denial of liability (number of orders meeting criteria)	0	0%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (number of judgments or consent decrees meeting criteria)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (number of counts)	0	0%
Emissions	Chronic excessive emissions events (number of events)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (number of audits for which notices were submitted)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (number of audits for which violations were disclosed)	0	0%
Please Enter Yes or No			
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 0%

>> Repeat Violator (Subtotal 3)

No

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

High Performer

Adjustment Percentage (Subtotal 7) -10%

>> Compliance History Summary

Compliance
History
Notes

Adjustment due to High Performer classification.

Total Adjustment Percentage (Subtotals 2, 3, & 7) -10%

Screening Date 6-Aug-2007 Respondent A R H Enterprises, Inc. dba R H Food Mart Case ID No. 34400 Reg. Ent. Reference No. RN102455748 Media [Statute] Petroleum Storage Tank Enf. Coordinator Judy Kluge Violation Number 1	Docket No. 2007-1261-PST-E PCW <small>Policy Revision 2 (September 2002)</small> <small>PCW Revision June 26, 2007</small>																				
Rule Cite(s) 30 Tex. Admin. Code § 334.50(a)(1)(A), (b)(2), (b)(2)(A)(i)(III) and Tex. Water Code § 26.3475(a) and (c)(1)																					
Violation Description Failed to provide a method of release detection capable of detecting a release from any portion of the UST system which contained regulated substances. Specifically, monthly inventory control was not being conducted and the automatic tank gauge did not have probes installed. Failed to conduct proper release detection for the product piping associated with the UST system. Specifically, the annual piping tightness tests had not been conducted. Failed to test the line leak detectors at least once per year for performance and operational reliability. Specifically, the line leak detectors had not been performance tested annually.																					
Base Penalty \$10,000																					
>> Environmental, Property and Human Health Matrix																					
OR	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: center;">Harm</td> <td style="width: 15%;"></td> <td style="width: 15%;"></td> <td style="width: 15%;"></td> </tr> <tr> <td></td> <td style="text-align: center;">Major</td> <td style="text-align: center;">Moderate</td> <td style="text-align: center;">Minor</td> <td></td> </tr> <tr> <td style="text-align: center;">Release Actual</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align: center;">Potential</td> <td style="text-align: center;">x</td> <td></td> <td></td> <td></td> </tr> </table> <div style="text-align: right; margin-top: 5px;"> Percent 25% </div>		Harm					Major	Moderate	Minor		Release Actual					Potential	x			
	Harm																				
	Major	Moderate	Minor																		
Release Actual																					
Potential	x																				
>> Programmatic Matrix																					
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: center;">Major</td> <td style="width: 15%; text-align: center;">Moderate</td> <td style="width: 15%; text-align: center;">Minor</td> </tr> <tr> <td style="text-align: center;">Falsification</td> <td></td> <td></td> <td></td> </tr> </table> <div style="text-align: right; margin-top: 5px;"> Percent 0% </div>		Major	Moderate	Minor	Falsification															
	Major	Moderate	Minor																		
Falsification																					
Matrix Notes	Human health or the environment will or could be exposed to pollutants which would exceed levels that are protective of human health or environmental receptors as a result of the violation.																				
Adjustment \$7,500																					
\$2,500																					
Violation Events																					
	<div style="display: flex; justify-content: space-between;"> Number of Violation Events 1 31 Number of violation days </div> <div style="margin-top: 10px;"> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: center;">daily</td> <td style="width: 15%;"></td> </tr> <tr> <td></td> <td style="text-align: center;">monthly</td> <td></td> </tr> <tr> <td style="text-align: center;">mark only one with an x</td> <td style="text-align: center;">quarterly</td> <td style="text-align: center;">x</td> </tr> <tr> <td></td> <td style="text-align: center;">semiannual</td> <td></td> </tr> <tr> <td></td> <td style="text-align: center;">annual</td> <td></td> </tr> <tr> <td></td> <td style="text-align: center;">single event</td> <td></td> </tr> </table> </div> <div style="text-align: right; margin-top: 10px;"> Violation Base Penalty \$2,500 </div>		daily			monthly		mark only one with an x	quarterly	x		semiannual			annual			single event			
	daily																				
	monthly																				
mark only one with an x	quarterly	x																			
	semiannual																				
	annual																				
	single event																				
One quarterly event is recommended based on documentation of the violation during the July 6, 2007 investigation to the August 6, 2007 screening date.																					
<div style="display: flex; justify-content: space-between;"> Economic Benefit (EB) for this violation Statutory Limit Test </div>																					
	<div style="display: flex; justify-content: space-between;"> Estimated EB Amount \$1,152 Violation Final Penalty Total \$2,964 </div>																				
This violation Final Assessed Penalty (adjusted for limits) \$2,964																					

Economic Benefit Worksheet**Respondent** A R H Enterprises, Inc. dba R H Food Mart**Case ID No.** 34400**Reg. Ent. Reference No.** RN102455748**Media** Petroleum Storage Tank**Violation No.** 1

Percent Interest	Years of Depreciation
5.0	15

Item Cost	Date Required	Final Date	Yrs	Interest Saved	Overtime Costs	EB Amount
Item Description	No comments					

Delayed Costs

Equipment				0.0	\$0	\$0	\$0
Buildings				0.0	\$0	\$0	\$0
Other (as needed)				0.0	\$0	\$0	\$0
Engineering/construction				0.0	\$0	\$0	\$0
Land				0.0	\$0	n/a	\$0
Record Keeping System				0.0	\$0	n/a	\$0
Training/Sampling				0.0	\$0	n/a	\$0
Remediation/Disposal				0.0	\$0	n/a	\$0
Permit Costs				0.0	\$0	n/a	\$0
Other (as needed)	\$1,500	6-Jul-2007	3-Apr-2008	0.7	\$56	n/a	\$56

Notes for DELAYED costs

Estimated cost to provide a method of release detection for the USTs. The date required is the investigation date and the final date is the expected date of compliance.

Avoided Costs**ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)**

Disposal				0.0	\$0	\$0	\$0
Personnel				0.0	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.0	\$0	\$0	\$0
Supplies/equipment				0.0	\$0	\$0	\$0
Financial Assurance [2]				0.0	\$0	\$0	\$0
ONE-TIME avoided costs [3]	\$1,000	6-Jul-2006	11-Jul-2007	1.9	\$97	\$1,000	\$1,097
Other (as needed)				0.0	\$0	\$0	\$0

Notes for AVOIDED costs

Avoided cost for conducting piping tightness and line leak detector tests. The date required is one year prior to the investigation date and the final date is the compliance date.

Approx. Cost of Compliance**\$2,500****TOTAL****\$1,152**

Screening Date 6-Aug-2007

Docket No. 2007-1261-PST-E

PCW

Respondent A R H Enterprises, Inc. dba R H Food Mart

Policy Revision 2 (September 2002)

Case ID No. 34400

PCW Revision June 26, 2007

Reg. Ent. Reference No. RN102455748

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Judy Kluge

Violation Number 2

Rule Cite(s) 30 Tex. Admin. Code § 115.248(1) and Tex. Health & Safety Code § 382.085(b)

Violation Description

Failed to ensure that at least one Station representative received training in the operation and maintenance of the Stage II vapor recovery system, and each current employee receives in-house Stage II vapor recovery training regarding the purpose and operation of the vapor recovery system. Specifically, Stage II training for the Station representative and the employees had not been completed.

Base Penalty \$10,000

>> Environmental, Property and Human Health Matrix

OR

Release	Harm		
	Major	Moderate	Minor
Actual			
Potential		x	

Percent 10%

>> Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0%

Matrix Notes

Human health or the environment will or could be exposed to significant amounts of pollutants which would not exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment \$9,000

\$1,000

Violation Events

Number of Violation Events 1

31 Number of violation days

mark only one with an x	daily	
	monthly	
	quarterly	x
	semiannual	
	annual	
	single event	

Violation Base Penalty \$1,000

One quarterly event is recommended based on documentation of the violation during the July 6, 2007 investigation to the July 18, 2007 compliance date.

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$1

Violation Final Penalty Total \$1,186

This violation Final Assessed Penalty (adjusted for limits) \$1,186

Economic Benefit Worksheet**Respondent** A R H Enterprises, Inc. dba R H Food Mart**Case ID No.** 34400**Reg. Ent. Reference No.** RN102455748**Media** Petroleum Storage Tank**Violation No.** 2

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
No dommas or \$							

Delayed Costs

Equipment				0.0	\$0	\$0	\$0
Buildings				0.0	\$0	\$0	\$0
Other (as needed)				0.0	\$0	\$0	\$0
Engineering/construction				0.0	\$0	\$0	\$0
Land				0.0	\$0	n/a	\$0
Record Keeping System				0.0	\$0	n/a	\$0
Training/Sampling				0.0	\$0	n/a	\$0
Remediation/Disposal				0.0	\$0	n/a	\$0
Permit Costs				0.0	\$0	n/a	\$0
Other (as needed)	\$500	6-Jul-2007	18-Jul-2007	0.0	\$1	n/a	\$1

Notes for DELAYED costs

Estimated cost of training Stage II Station representative. The date required is the investigation date and the final date is the date of compliance.

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

Disposal				0.0	\$0	\$0	\$0
Personnel				0.0	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.0	\$0	\$0	\$0
Supplies/equipment				0.0	\$0	\$0	\$0
Financial Assurance [2]				0.0	\$0	\$0	\$0
ONE-TIME avoided costs [3]				0.0	\$0	\$0	\$0
Other (as needed)				0.0	\$0	\$0	\$0

Notes for AVOIDED costs

Approx. Cost of Compliance

\$500

TOTAL

\$1

Screening Date 6-Aug-2007

Docket No. 2007-1261-PST-E

PCW

Respondent A R H Enterprises, Inc. dba R H Food Mart

Policy Revision 2 (September 2002)

Case ID No. 34400

PCW Revision June 26, 2007

Reg. Ent. Reference No. RN102455748

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Judy Kluge

Violation Number 3

Rule Cite(s) 30 Tex. Admin. Code § 115.242(1)(C), (3), and (9) and Tex. Health & Safety Code § 382.085(b)

Violation Description

Failed to upgrade the Stage II equipment to onboard refueling vapor recovery (ORVR) compatible systems. Failed to maintain the Stage II Vapor Recovery System in proper operating condition, as specified by the manufacturer and/or any applicable CARB Executive Order(s), and free of defects that would impair the effectiveness of the system including, but not limited to absence or disconnection of any component that is a part of the approved system. Specifically, the Stage II air to liquid test indicated that the nozzles were defective and not functioning properly. Failed to post operating instructions conspicuously on the front of each gasoline dispensing pump.

Base Penalty \$10,000

>> Environmental, Property and Human Health Matrix

OR

	Harm		
Release	Major	Moderate	Minor
Actual			
Potential		x	

Percent 10%

>> Programmatic Matrix

	Falsification	Major	Moderate	Minor

Percent 0%

Matrix Notes

Human health or the environment will or could be exposed to significant amounts of pollutants which would not exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment \$9,000

\$1,000

Violation Events

Number of Violation Events 1

31 Number of violation days

mark only one with an x	daily	
	monthly	
	quarterly	x
	semiannual	
	annual	
	single event	

Violation Base Penalty \$1,000

One quarterly event is recommended based on documentation of the violation during the July 6, 2007 investigation to the August 6, 2007 screening date.

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$66

Violation Final Penalty Total \$1,186

This violation Final Assessed Penalty (adjusted for limits) \$1,186

Economic Benefit Worksheet**Respondent** A R H Enterprises, Inc. dba R H Food Mart**Case ID No.** 34400**Reg. Ent. Reference No.** RN102455748**Media** Petroleum Storage Tank**Violation No.** 3

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
No commas or \$							

Delayed Costs

Equipment	\$2,500	6-Jul-2007	20-Nov-2007	0.4	\$3	\$63	\$66
Buildings				0.0	\$0	\$0	\$0
Other (as needed)				0.0	\$0	\$0	\$0
Engineering/construction				0.0	\$0	\$0	\$0
Land				0.0	\$0	n/a	\$0
Record Keeping System				0.0	\$0	n/a	\$0
Training/Sampling				0.0	\$0	n/a	\$0
Remediation/Disposal				0.0	\$0	n/a	\$0
Permit Costs				0.0	\$0	n/a	\$0
Other (as needed)				0.0	\$0	n/a	\$0

Notes for DELAYED costs

Estimated cost to upgrade the Stage II equipment to ORVR compatible systems, repair or replace the defective nozzles, and post operating instructions on the dispensers. The date required is the investigation date and the final date is the date of compliance.

Avoided Costs**ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)**

Disposal				0.0	\$0	\$0	\$0
Personnel				0.0	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.0	\$0	\$0	\$0
Supplies/equipment				0.0	\$0	\$0	\$0
Financial Assurance [2]				0.0	\$0	\$0	\$0
ONE-TIME avoided costs [3]				0.0	\$0	\$0	\$0
Other (as needed)				0.0	\$0	\$0	\$0

Notes for AVOIDED costs**Approx. Cost of Compliance****\$2,500****TOTAL****\$66**

Screening Date 6-Aug-2007

Docket No. 2007-1261-PST-E

PCW

Respondent A R H Enterprises, Inc. dba R H Food Mart

Policy Revision 2 (September 2002)

Case ID No. 34400

PCW Revision June 26, 2007

Reg. Ent. Reference No. RN102455748

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Judy Kluge

Violation Number 4

Rule Cite(s)

30 Tex. Admin. Code § 115.245(2) and Tex. Health & Safety Code § 382.085(b)

Violation Description

Failed to verify proper operation of the Stage II equipment at least once every 12 months. Specifically, the Stage II annual system compliance testing had not been conducted.

Base Penalty \$10,000

>> Environmental, Property and Human Health Matrix

OR

	Harm		
Release	Major	Moderate	Minor
Actual			
Potential	x		

Percent 25%

>> Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0%

Matrix Notes

Human health or the environment will or could be exposed to pollutants which would exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment \$7,500

\$2,500

Violation Events

Number of Violation Events 1

365 Number of violation days

mark only one with an x	daily	
	monthly	
	quarterly	
	semiannual	
	annual	x
	single event	

Violation Base Penalty \$2,500

One annual event is recommended for the 12 month period preceding the July 6, 2007 investigation.

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$1,115

Violation Final Penalty Total \$2,964

This violation Final Assessed Penalty (adjusted for limits) \$2,964

Economic Benefit Worksheet**Respondent** A R H Enterprises, Inc. dba R H Food Mart**Case ID No.** 34400**Reg. Ent. Reference No.** RN102455748**Media** Petroleum Storage Tank**Violation No.** 4

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
No commas or \$							

Delayed Costs

Equipment				0.0	\$0	\$0	\$0
Buildings				0.0	\$0	\$0	\$0
Other (as needed)				0.0	\$0	\$0	\$0
Engineering/construction				0.0	\$0	\$0	\$0
Land				0.0	\$0	n/a	\$0
Record Keeping System				0.0	\$0	n/a	\$0
Training/Sampling				0.0	\$0	n/a	\$0
Remediation/Disposal				0.0	\$0	n/a	\$0
Permit Costs				0.0	\$0	n/a	\$0
Other (as needed)				0.0	\$0	n/a	\$0

Notes for DELAYED costs

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

Disposal				0.0	\$0	\$0	\$0
Personnel				0.0	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.0	\$0	\$0	\$0
Supplies/equipment				0.0	\$0	\$0	\$0
Financial Assurance [2]				0.0	\$0	\$0	\$0
ONE-TIME avoided costs [3]	\$1,000	6-Jul-2006	20-Nov-2007	2.3	\$115	\$1,000	\$1,115
Other (as needed)				0.0	\$0	\$0	\$0

Notes for AVOIDED costs

Estimated cost for annual testing to verify proper operation of the Stage II equipment. The date required is the one year prior to the investigation date and the final date is the compliance date.

Approx. Cost of Compliance

\$1,000

TOTAL

\$1,115

Compliance History

Customer/Respondent/Owner-Operator:	CN602949042	A R H Enterprises, Inc.	Classification: HIGH	Rating: 0.00
Regulated Entity:	RN102455748	R H FOOD MART	Classification: HIGH	Site Rating: 0.00
ID Number(s):	PETROLEUM STORAGE TANK REGISTRATION	REGISTRATION	66942	
Location:	3701 ESTERS RD, IRVING, TX, 75038	Rating Date: 9/1/2006	Repeat Violator: NO	
TCEQ Region:	REGION 04 - DFW METROPLEX			
Date Compliance History Prepared:	August 06, 2007			
Agency Decision Requiring Compliance History:	Enforcement			
Compliance Period:	August 06, 2002 to August 06, 2007			

TCEQ Staff Member to Contact for Additional Information Regarding this Compliance History

Name: Judy Kluge Phone: 817-588-5825

Site Compliance History Components

1. Has the site been in existence and/or operation for the full five year compliance period? Yes
2. Has there been a (known) change in ownership of the site during the compliance period? Yes
3. If Yes, who is the current owner? A R H Enterprises, Inc.
4. If Yes, who was/were the prior owner(s)? New American Investment Group, Inc.
5. When did the change(s) in ownership occur? 10/10/2005

Components (Multimedia) for the Site :

- A. Final Enforcement Orders, court judgements, and consent decrees of the state of Texas and the federal government.
N/A
 - B. Any criminal convictions of the state of Texas and the federal government.
N/A
 - C. Chronic excessive emissions events.
N/A
 - D. The approval dates of investigations. (CCEDS Inv. Track. No.)
1 03/16/2004 (263002)
2 08/03/2007 (567584)
 - E. Written notices of violations (NOV). (CCEDS Inv. Track. No.)
 - F. Environmental audits.
N/A
 - G. Type of environmental management systems (EMSs).
N/A
 - H. Voluntary on-site compliance assessment dates.
N/A
 - I. Participation in a voluntary pollution reduction program.
N/A
 - J. Early compliance.
N/A
- Sites Outside of Texas
N/A

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
A R H ENTERPRISES, INC. DBA R H
FOOD MART
RN102455748

§ BEFORE THE
§
§ TEXAS COMMISSION ON
§
§ ENVIRONMENTAL QUALITY

AGREED ORDER DOCKET NO. 2007-1261-PST-E

I. JURISDICTION AND STIPULATIONS

At its _____ agenda, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding A R H Enterprises, Inc. dba R H Food Mart ("the Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 382 and TEX. WATER CODE chs. 7 and 26. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent appear before the Commission and together stipulate that:

1. The Respondent owns and operates a convenience store with retail sales of gasoline at 3701 Esters Road in Irving, Dallas County, Texas (the "Station").
2. The Respondent's three underground storage tanks ("USTs") are not exempt or excluded from regulation under the Texas Water Code or the rules of the Commission. The Station consists of one or more sources as defined in TEX. HEALTH & SAFETY CODE § 382.003(12).
3. The Commission and the Respondent agree that the Commission has jurisdiction to enter this Agreed Order, and that the Respondent is subject to the Commission's jurisdiction.
4. The Respondent received notice of the violations alleged in Section II ("Allegations") on or about August 8, 2007.
5. The occurrence of any violation is in dispute and the entry of this Agreed Order shall not constitute an admission by the Respondent of any violation alleged in Section II ("Allegations"), nor of any statute or rule.

6. An administrative penalty in the amount of Eight Thousand Three Hundred Dollars (\$8,300) is assessed by the Commission in settlement of the violations alleged in Section II ("Allegations"). The Respondent has paid Two Hundred Dollars (\$200) of the administrative penalty and One Thousand Six Hundred Sixty Dollars (\$1,660) is deferred contingent upon the Respondent's timely and satisfactory compliance with all the terms of this Agreed Order. If the Respondent fails to timely and satisfactorily comply with all requirements of this Agreed Order, including the payment schedule, the Executive Director may require the Respondent to pay all or part of the deferred penalty.

The remaining amount of Six Thousand Four Hundred Forty Dollars (\$6,440) of the administrative penalty shall be payable in 35 monthly payments of One Hundred Eighty-Four Dollars (\$184) each. The next monthly payment shall be paid within 30 days after the effective date of this Agreed Order. The subsequent payments shall each be paid not later than 30 days following the due date of the previous payment until paid in full. If the Respondent fails to timely and satisfactorily comply with the payment requirements of this Agreed Order, the Executive Director may, at the Executive Director's option, accelerate the maturity of the remaining installments, in which event the unpaid balance shall become immediately due and payable without demand or notice. In addition, the failure of the Respondent to meet the payment schedule of this Agreed Order constitutes the failure by the Respondent to timely and satisfactorily comply with all the terms of this Agreed Order.

7. Any notice and procedures, which might otherwise be authorized or required in this action, are waived in the interest of a more timely resolution of the matter.
8. The Executive Director of the TCEQ and the Respondent have agreed on a settlement of the matters alleged in this enforcement action, subject to the approval of the Commission.
9. The Executive Director recognizes that the Respondent has implemented the following corrective measures at the Station:
 - a. The TCEQ Dallas/Fort Worth Regional Office received documentation verifying that as of July 11, 2007, the Station successfully conducted the required piping tightness and line leak detector tests;
 - b. The TCEQ Dallas/Fort Worth Regional Office received documentation verifying that Station representative training has been completed and all current employees have received in-house Stage II vapor recovery training as of July 18, 2007;
 - c. As of November 20, 2007, the TCEQ Dallas/Fort Worth Regional Office received verification that the Respondent installed an approved onboard refueling vapor recovery ("ORVR") compatible Stage II vapor recovery system, replaced the defective nozzles, and posted the Stage II operating instructions on the dispensers; and
 - d. As of November 20, 2007, the TCEQ Dallas/Fort Worth Regional Office received verification that the Respondent successfully conducted the required annual testing of the Stage II equipment.
10. The Executive Director may, without further notice or hearing, refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings if the

Executive Director determines that the Respondent has not complied with one or more of the terms or conditions in this Agreed Order.

11. This Agreed Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Agreed Order, whichever is later.
12. The provisions of this Agreed Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Agreed Order unenforceable, the remaining provisions shall be valid and enforceable.

II. ALLEGATIONS

As owner and operator of the Station, the Respondent is alleged to have:

1. Failed to provide a method of release detection capable of detecting a release from any portion of the UST system which contained regulated substances, in violation of 30 TEX. ADMIN. CODE § 334.50(a)(1)(A) and TEX. WATER CODE § 26.3475(c)(1), as documented during an investigation conducted on July 6, 2007. Specifically, monthly inventory control was not being conducted and the automatic tank gauge did not have probes installed.
2. Failed to conduct proper release detection for the product piping associated with the UST system, in violation of 30 TEX. ADMIN. CODE § 334.50(b)(2) and TEX. WATER CODE § 26.3475(a), as documented during an investigation conducted on July 6, 2007. Specifically, the annual piping tightness tests had not been conducted.
3. Failed to test the line leak detectors at least once per year for performance and operational reliability, in violation of 30 TEX. ADMIN. CODE § 334.50(b)(2)(A)(i)(III) and TEX. WATER CODE § 26.3475(a), as documented during an investigation conducted on July 6, 2007. Specifically, the line leak detectors had not been performance tested annually.
4. Failed to ensure that at least one Station representative received training in the operation and maintenance of the Stage II vapor recovery system, and each current employee receives in-house Stage II vapor recovery training regarding the purpose and operation of the vapor recovery system, in violation of 30 TEX. ADMIN. CODE § 115.248(1) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on July 6, 2007. Specifically, Stage II training for the Station representative and the employees had not been completed.
5. Failed to upgrade the Stage II equipment to ORVR compatible systems, in violation of 30 TEX. ADMIN. CODE § 115.242(1)(C) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on July 6, 2007.
6. Failed to maintain the Stage II Vapor Recovery System in proper operating condition, as specified by the manufacturer and/or any applicable California Air Resource Board Executive Order(s), and free of defects that would impair the effectiveness of the system including, but not limited to absence or disconnection of any component that is a part of the approved system, in violation of 30 TEX. ADMIN. CODE § 115.242(3) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on July 6, 2007. Specifically, the Stage II air to liquid test indicated that the nozzles were defective and not functioning properly.

7. Failed to post operating instructions conspicuously on the front of each gasoline dispensing pump, in violation of 30 TEX. ADMIN. CODE § 115.242(9) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on July 6, 2007.
8. Failed to verify proper operation of the Stage II equipment at least once every 12 months, in violation of 30 TEX. ADMIN. CODE § 115.245(2) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on July 6, 2007. Specifically, the Stage II annual system compliance testing had not been conducted.

III. DENIALS

The Respondent generally denies each allegation in Section II ("Allegations").

IV. ORDERING PROVISIONS

1. It is, therefore, ordered by the TCEQ that the Respondent pay an administrative penalty as set forth in Section I, Paragraph 6 above. The payment of this administrative penalty and the Respondent's compliance with all the terms and conditions set forth in this Agreed Order resolve only the allegations in Section II. The Commission shall not be constrained in any manner from requiring corrective action or penalties for violations, which are not raised here. Administrative penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: A R H Enterprises, Inc. dba R H Food Mart, Docket No. 2007-1261-PST-E" to:

Financial Administration Division, Revenues Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088

2. It is further ordered that the Respondent shall undertake the following technical requirements:
 - a. Within 30 days after the effective date of this Agreed Order, install and implement a release detection method for the UST system, in accordance with 30 TEX. ADMIN. CODE § 334.50.
 - b. Within 45 days after the effective date of this Agreed Order, submit written certification as described below, and include detailed supporting documentation including photographs, receipts, and/or other records to demonstrate compliance with Ordering Provision No. 2.a. The certification shall be notarized by a State of Texas Notary Public and include the following certification language:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are

significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

The certification shall be submitted to:

Order Compliance Team
Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

with a copy to:

Waste Section Manager
Dallas/Fort Worth Regional Office
Texas Commission on Environmental Quality
2309 Gravel Drive
Fort Worth, Texas 76118-6951

3. The provisions of this Agreed Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of the Agreed Order to personnel who maintain day-to-day control over the Station operations referenced in this Agreed Order.
4. If the Respondent fails to comply with any of the Ordering Provisions in this Agreed Order within the prescribed schedules, and that failure is caused solely by an act of God, war, strike, riot, or other catastrophe, the Respondent's failure to comply is not a violation of this Agreed Order. The Respondent shall have the burden of establishing to the Executive Director's satisfaction that such an event has occurred. The Respondent shall notify the Executive Director within seven days after the Respondent becomes aware of a delaying event and shall take all reasonable measures to mitigate and minimize any delay.
5. The Executive Director may grant an extension of any deadline in this Agreed Order or in any plan, report, or other document submitted pursuant to this Agreed Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director.
6. This Agreed Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Agreed Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.
7. This agreement may be executed in multiple counterparts, which together shall constitute a single original instrument. Any executed signature page to this Agreement may be transmitted by facsimile transmission to the other parties, which shall constitute an original signature for all purposes.

8. Under 30 TEX. ADMIN. CODE § 70.10(b), the effective date is the date of hand-delivery of the Order to the Respondent, or three days after the date on which the Commission mails notice of the Order to the Respondent, whichever is earlier. The Chief Clerk shall provide a copy of this Agreed Order to each of the parties.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission



For the Executive Director


Date 1/21/2008

I, the undersigned, have read and understand the attached Agreed Order. I am authorized to agree to the attached Agreed Order on behalf of the entity indicated below my signature, and I do agree to the terms and conditions specified therein. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I also understand that failure to comply with the Ordering Provisions, if any, in this order and/or failure to timely pay the penalty amount, may result in:


- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution..




Signature

Date 11-28-07



Name (Printed or typed)
Authorized Representative of
A R H Enterprises, Inc. dba R H Food Mart



Title

Instructions: Send the original, signed Agreed Order with penalty payment to the Financial Administration Division, Revenues Section at the address in Section IV, Paragraph 1 of this Agreed Order.

